


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1155 / 13.07.2011**

NUMBER	1155	DATE	13 / 07 / 2011
---------------	-------------	-------------	-----------------------

Client' s data:	Alumil S.A. ALUMINIUM INDUSTRY KILKIS INDUSTRIAL AREA GR 611 00 KILKIS GREECE
Product description:	Double Sash Window Lift & Slide
Material:	ALUMINIUM
System :	S 700



2220 x 1800mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3	
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4	
Classification according to use of external water collector length	Partial use of external water collector length	Full use of external water collector length
Watertightness – Method B <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 2B	Class 7B
Watertightness – Method A <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 2A	Class 6A

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPA DOPOULOU
LABORATORY MANAGER**



**KONSTANTINOS KATSAROS
MANAGING DIRECTOR**

EXACT TRANSLATION FROM THE GREEK ORIGINAL